



SCOPE

1.00 These specifications cover the general material, and fabrication standards employed by Kencoil in the manufacture of ac stator coils operating at voltage ratings up to and including 7200 volts.

STANDARDS

2.00 All coils manufactured under these specifications are done so in accordance with the latest published IEEE and NEMA Standards unless otherwise specified.

MATERIALS

3.00 All materials are compatible and unless otherwise specified will be compatible with standard materials used in the industry. Materials meet or exceed class "F" temperature ratings.

4.00 Conductors used are high conductivity 100% virgin copper.

5.00 Conductor strand insulation shall be quad film covered wire with a polyester basecoat and a polyamideimide topcoat.

5.01 Additional supplemental turn insulation (if required), will consist of either a single or double fused glass over quad wire or supplemental taped mica or polyimide film turn insulation as required.

5.02 Strand insulation choice is determined from any of the following factors:

- A. RMS volts between turns
- B. Available slot space
- C. Machine application

6.00 The end turn insulation shall consist of a mica tape typically .0065" thick, ¾ lapped, with the minimum servings as indicated below:

Voltage	No. of Servings
Thru 600	1
2300	2
4160	3
7200	5

7.00 The ground wall insulation shall be a mica tape or mica wrapper type insulation, or a combination of both, applied to the typical thickness as indicated below:

Voltage	Thickness
Thru 600	.013"
2300	.039"
4160	.052"
7200	.078"

8.00 The lead insulation for various voltages shall be as indicated below:

Voltage	Type
Thru 4160	Fiberglass braid over acrylic
7200	No less than 2 servings of ½ laps, .0065" mica or .001" polyimide film under fiberglass braid over acrylic

9.00 The outer protective armor tape consists of one serving, ½ lapped, .005 thick polyester Dacron. Coils for machines operating above 5000 volts and intended to receive a V.P.I. application will have conductive tape for corona protection on the straight sections of stator coils. Conductive paint is used for corona protection on the straight sections of varnish treated coils operating above 5000 volts.

CONSTRUCTION

10.00 Coils are shuttle wound, hydraulically press molded to assure conductor alignment and may be varnish submerged, and oven cured.

11.00 The loops have the lead insulation wiped clean to bare copper; are spread to proper shape, and checked for uniformity prior to receiving any insulation.

12.00 Leads are taped and/or sleeved. The prescribed servings of mica ground-wall tape are applied by machine. If prescribed a single continuous sheet of mica material is wrapped around the full straight length of the slot sections.

13.00 A final armor tape is machine applied. The coils are totally submerged in varnish, lead end up, to a point just covering the insulation. Coils are fully baked in the oven to assure thorough drying of the varnish, yet maintain a degree of flexibility for ease of insertion.

13.01 Coils wound in machines intended for V.P.I. application will by-pass the varnish treatment in 13.00.

13.02 The straight sections of varnish treated coils operating above 5000 volts are painted with anti-corona, conductive paint and the straight sections of V.P.I. coils are covered with anti-corona, conductive tape. The intent of corona protection is to equalize voltage stress between the core slot side and the coil thus preventing corona discharges from occurring.

TESTING

14.00 Prior to shipment a random sampling of coils must pass a dc ground test of twice normal operating voltage for one minute. Coils must pass a ten second high frequency turn to turn insulation test as follows:

Strand Ins.	Applied Voltage
Heavy Film	Turns per coil x 500 = test volt
Quad Film	Turns per coil x 850 = test volt
[Single glass over	add 200 volts/turn]
[Double glass over	add 400 volts/turn]
[Polyimide film over	add 300 volts/turn]
[Mica over	add 1,300 volts/turn]

TESTING (COMPLETED WINDING)

14.01 The following test values are recommended when applying D.C. voltage to a completed winding:

Before V.P.I. processing	100% of line voltage
After V.P.I. processing	(2E + 1000) x 1.7

GUARANTEE

15.00 Kencoil, Inc. guarantees its manufactured products to be free of defective materials and workmanship. It further guarantees the coils will pass the standard hi-pot and surge tests after complete insertion and proper connections are made. This guarantee remains in effect for one year from date of our invoice. Exceptions will be taken should the end user, through neglect or abuse, allow the machine to become victim of faulty electrical, mechanical, or environmental circumstances.

