



SCOPE

1.00 These specifications cover the general material, and fabrication standards employed by Kencoil in the manufacture of ac stator coils operating at voltage ratings up to and including 7200 volts.

STANDARDS

2.00 All coils manufactured under these specifications are done so in accordance with the latest published IEEE and NEMA Standards unless otherwise specified.

MATERIALS

3.00 All materials are compatible and unless otherwise specified will be compatible with standard materials used in the industry. Materials meet or exceed class "F" temperature ratings.

4.00 Conductors used are high conductivity 100% virgin copper.

5.00 Conductor strand insulation shall be heavy or quad film covered wire with a polyester basecoat and a polyamideimide topcoat or fused single or double glass served over a heavy or quad film covered wire. Other supplemental turn insulation (if required), will consist of taped mica.

5.01 Strand insulation choice is determined from any of the following factors:

- A. RMS volts between turns
- B. Available slot space
- C. Machine application

6.00 The end turn insulation shall consist of a .007" thick mica tape, typically ¾ lapped, with the minimum servings as indicated below:

Voltage	No. of Servings
Thru 600	1
2300	1
4160	2
7200	4

7.00 The ground wall insulation shall be a mica tape typically applied to the thickness between conductor and core as indicated below:

Voltage	Thickness
Thru 600	.014"
2300	.042"
4160	.056"
7200	.084"

8.00 The lead insulation for various voltages shall be as indicated below:

Voltage	Type
Thru 4160	No less than 3 servings of ½ lap, .007" mica overlaid with one serving of untreated raw fiberglass sleeving
7200	No less than 5 servings of ½ lap, .007" mica overlaid with one serving of untreated raw fiberglass sleeving

9.00 The outer protective armor tape consists of one serving, ½ lapped, .005" thick, polyester Dacron,

CONSTRUCTION

10.00 Coils are shuttle wound, hydraulically press molded to assure conductor alignment and may be varnish submerged, and oven cured.

11.00 The loops have the lead insulation wiped clean to bare copper; are spread to proper shape, and checked for uniformity.

12.00 Leads are sleeved and/or taped. The prescribed servings of mica ground-wall tape are applied by machine.

13.00 A final armor tape is machine applied. The coils may be oven baked to assure thorough drying of the insulation system.

TESTING

14.00 Prior to shipment a sample of coils must pass a dc ground test of twice normal operating voltage for one minute. Coils must pass a ten second surge test (high frequency turn to turn insulation test) as follows:

Strand Ins.	Applied Voltage
Heavy Film	Turns per coil x 500 = test volt
Quad Film	Turns per coil x 850 = test volt
[Single glass over	add 200 volts/turn]
[Double glass over	add 400 volts/turn]
[Mica over	add 1,300 volts/turn]

TESTING (COMPLETED WINDING)

14.01 The following test values are recommended when applying D.C. voltage to a completed winding:

Before V.P.I. processing	100% of line voltage
After V.P.I. processing	(2E + 1000) x 1.7

GUARANTEE

15.00 Kencoil, Inc. guarantees its manufactured products to be free of defective materials and workmanship. It further guarantees the coils will pass the standard hi-pot and surge tests after complete insertion and proper connections are made. This guarantee remains in effect for one year from date of our invoice. Exceptions will be taken should the end user, through neglect or abuse, allow the machine to become victim of faulty electrical, mechanical, or environmental circumstances.

